



**LOCAL AND COLLECTOR (SN<sub>R</sub> 3.5 MIN.)**

- FINISH COURSE: 1"-1 ½" Type SP 9.5
- STRUCTURAL COURSE: 1 ½"-2 ½" Type SP-12.5 Asphaltic Concrete
- BASE COURSE: Optional Base Group 5 per FDOT Standard Specification Section 285
- SUBGRADE: 12" Compacted or Stabilized Subgrade (LBR-40)

**COMMERCIAL/INDUSTRIAL - SN<sub>R</sub> 4.0 (AS DIRECTED BY CITY)**

- FINISH COURSE: 1"-1 ½" Type SP 9.5
- STRUCTURAL COURSE: 1 ½"-2 ½" Type SP-12.5 Asphaltic Concrete
- BASE COURSE: Optional Base Group 9 per FDOT Standard Specification Section 285
- SUBGRADE: 12" Compacted or Stabilized Subgrade (LBR-40)

**Notes:**

1. Minimum Structural course thickness shall be 1 ½".
2. Shoulder design:  
 Surface course: Same as travel lane surface course.  
 Base course: Optional base Group 4 per FDOT Standard Specification Section 285
3. Required Structural Number (SN<sub>R</sub>) per FDOT Flexible Pavement Design Manual.
4. Substitutions may be approved by City of West Palm Beach, provided minimum SN<sub>R</sub> is demonstrated.

LATEST REVISION 2019	GENERAL CONSTRUCTION - FLEXIBLE PAVEMENT SECTION	STANDARD DETAIL
	CITY OF WEST PALM BEACH - ENGINEERING SERVICES	GC-4